


Environmental Certification Scheme

Carpet Name: **COMPOSURE**



Licensee: **INTERFACE**
Licence Number: **1016**
Label Number: **18012**

Certification Approved: **28/02/2018**

Level: **4**

ACCS Contract Grading: **CHD 3***
ACCS Residential Grading: **NONE**
Suitable for Stairs: **Yes**

Date Printed: **27/05/2020**

Allan Firth



Allan Firth
Secretary ACCS



Administered by the Carpet Institute of Australia Limited ABN 11 006 829 303
PO Box 7172, St Kilda Road, Melbourne Victoria 8004 Tel: (03) 9804 5559 • Fax: (03) 9804 5560
Email: info@carpetoz.com.au • www.carpetinstitute.com.au

This certificate remains the property of the Carpet Institute of Australia Limited.

Carpet Details:

Company: INTERFACE

Label No: 18012

Licence No: 1016

Office No: 6618

Names:

COMPOSURE

Details:

Awarded Res Grade: NONE
 Awarded Con Grade: CHD 3*
 Registered On: 12/02/2018
 Active: Yes
 Date In-Active:
 Manufacture Method: Tufted
 Twist Set: N/A
 Dyeing Method: Melt Dyed
 #Colours/Designs: 12/
 Backing Type: OTHER
 Felted: N/A
 Spinning System: BCF
 Insect Resist Agent: N/A
 Filament: 18.75
 Master Product:

Test Results:

Pile Mass g/m² (oz/yd²): 543 (16.0)
 SPM g/m² (oz/yd²): 363.7 (10.7)
 Stated Pile Height (mm): 3.0
 Minimum Pile Height (mm): 0.0
 Maximum Pile Height (mm): 0.0
 Dynamic Loading Loss (%): 0.0
 Static Loading Loss (%): 0.0
 Tex (g/1000m): 266
 Measured Pile Thickness (mm): 2.9
 Machine Gauge (Tufts/dm): 47.0
 Meas Tufts Perp to Selvedge: 48.0
 Meas Tufts Para to Selvedge: 35.0
 Treated For Soiling Resistance: Yes
 Soil Resist Inhibitor: Yes
 Stain Resist Inhibitor: Yes

Hexapod Scores:

	Texture		Colour		Thickness	
	WA		WA		(mm)	(%)
1500:	4.0	0.0	4.0	0.0	0.4	13.8
8000:	3.0	0.0	3.0	0.0	0.9	31.0

Quality Assurance Test:

Cut Pile (%): 0
 Loop Pile (%): 100
 Panel Assessment Contract: 13
 Panel Assessment Residential: 13
 Suitable For Stairs: Yes
 Tile: Yes SheetGoods: No
 Fibre Signature: NBA:100

ACCS Test:

	Con	Res	Max
SPM/PH Ratio:	12.6	16	16
Volume Density:	11.7	11.7	20
Tuft Density:	8.2	8.2	9
Dyn Load:	3.9	3.9	5
Stat Load:	4.1	4.1	5
Soiling Prop:	14	14	16
Abrasion Res:	9.3	9.3	10
Sub Total:	63.8	67.2	81
Panel Assess:	13	13	19
Total:	76.8	80.2	100
Calc Residential Grade:	REHD2		6*
Calc Contract Grade:	CMD		2*

Calculations

Pile Height(mm): 4.2
 Tuft Density(per dm²): 1680.0
 GSPM(g/m²): 397.0
 GSPM (abrasive) (g/m²): 275.0
 Soiling Propensity: 12.0 +2.0

OAF Values

OAF: 4.2
 Calc Density (+-5%): 0.12 0.125 0.13
 Base Fibre: NYLON
 Benchmarks:
 RHD1 0 RHD2 3.5
 REHD1 3.5 REHD2 3.5

Environmental Classification:

ECS: Yes
 Level: 4

	Calc	B/M	P/F
Acoustic:	2.9	3	
Thermal:	23.1	15	PASS
VOC:			
TVOC	54		

Notes:

12/2/18 Submitted by J Azar. 28/2/18 Panel awarded CHD(S) 3* and ECS Level 4. 22/5/20 Re-grade test data entered. 27/5/2020 Re-graded as CHD(S) 3* and ECS Level 4.