

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Interface Australia Pty Ltd
34 Airds Road
Minto NSW 2566

Test Number : 15-002358
Issue Date : 12/06/2015
Print Date : 12/06/2015
Order Number : 37060

Sample Description Clients Ref : "Silver Lining SL910"
Striped loop pile carpet tile
Colour : Grey
Nominal Composition : 100% Solution Dyed Nylon 6
Nominal Mass per Unit Area/Density : 678g/m2 On a Glasbac Backing

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 22/05/2015
Date Tested 12/06/2015

CHF Value	1	2	3	Mean
Length	5.1	4.6	5.0	4.9 kW/m ²
Width	5.3	-	-	- kW/m ²

Smoke Value	1	2	3	Mean
Length	119	109	130	119 % .min
Width	129	-	-	- % .min

Melting Yes
Blistering Yes

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

26681

5029

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025
- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

[Signature]

APPROVED SIGNATORY

[Signature]
MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR