

Emission Test Certificate

Monday August 17th, 2009

Supplier: Interface Australia Pty Ltd (14 Henry Street, Picton NSW 2571)

Sample Description: Graphlex backed carpet tile

Date Tested: August 2009

Test Method: Carpet Institute of Australia Australian Carpet Classification Scheme incorporating Draft ISO/TC 219 Document N238 "Resilient, Textile and Laminate Floor Coverings: Evaluation of Volatile Organic Compound Emissions".

Emission Data:

Carpet Institute of Australia Environmental Certification Scheme Specification	Graphlex Backed Carpet Tile
Total Volatile Organic Compound emission rate <500 ug/m ² /hr	Total Volatile Organic Compound emission rate 75 ug/m ² /hr
Emission Rate "Chemicals of Concern": Acetaldehyde <20 ug/m ² /hr Benzene <55 ug/m ² /hr Caprolactam <120 ug/m ² /hr 2-Ethylhexanoic Acid <46 ug/m ² /hr Formaldehyde <10 ug/m ² /hr 1-Methyl-2-Pyrrolidinone <300 ug/m ² /hr Naphthalene <20 ug/m ² /hr Nonanal <24 ug/m ² /hr Octanal <24 ug/m ² /hr 4-Phenylcyclohexene <50 ug/m ² /hr Styrene <410 ug/m ² /hr Toluene <280 ug/m ² /hr Vinyl Acetate <400 ug/m ² /hr 2-Ethyl-1-Hexanol <50 ug/m ² /hr Hydrocarbons (C ₁₀ – C ₁₄) <300 ug/m ² /hr Vinyl Cyclohexene <85 ug/m ² /hr Xylenes <50 ug/m ² /hr	Emission Rate: 2 ug/m ² /hr <6 ug/m ² /hr <6ug/m ² /hr <6 ug/m ² /hr 9 ug/m ² /hr <6 ug/m ² /hr <6 ug/m ² /hr <6 ug/m ² /hr <6 ug/m ² /hr <6 ug/m ² /hr 10 ug/m ² /hr <6 ug/m ² /hr <6 ug/m ² /hr 40 ug/m ² /hr <6 ug/m ² /hr <6 ug/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV090726