

VOC Content Test Certificate

Wednesday August 18th, 2010

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137)

Sample Description: InterfaceFlor Seam Sealer

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	InterfaceFlor Seam Sealer
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	<50 grams per Litre as VOC content per material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	InterfaceFlor Seam Sealer
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	<50 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1008-11