



# Confirmation

Eurofins Product Testing A/S confirms that a sample of a textile floor covering with the name

## **Interface Tufted polyamide** supplied by **Interface**

Complies with the requirements specified in LEED credit EQ 4.3 for flooring systems.

The test has been performed in the time period of 24-05-2013 - 07-06-2013, see test report no. 2013-392-00009403. The test was conducted according to the "Standard Method for the Testing and Evaluation of VOC Emissions from Indoor Sources using Environmental Chambers", version 1.1 of February 2010 by the California Department of Public Health.

The testing methodology is covered by independent ISO 17025 accreditation, issued by DANAK (# 522).

**With this confirmation, use of product Interface carpet tile qualifies for fulfillment of LEED credit EQ 4.3 (flooring systems).**

---

19-06-2013

---

Dr. Arja Valtanen  
Analytical Service Manager

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK 8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75

[www.product-testing.eurofins.com](http://www.product-testing.eurofins.com)